

Woodland Pump & Supply  
P.O. Box 69  
Woodland Park, CO 80866

To Whom It May Concern:

October 17, 2019

Per your request a pump test was performed at 84 Caribou Circle, Florissant CO.  
**THE RECOVERY RATE AFTER THE TEST PROVED TO BE NINE (9) GALLONS PER MINUTE.** A total of 542 gallons of water were pumped out during this test, which took just over one hour to perform.

This well does not have a pump installed in it; It was tested using our ½ hp 10 gpm 2-wire submersible pump at a setting of 60 feet. This well is properly constructed and cased. The water pumped out dirty to start this test, after about 40 minutes it cleaned up and ran clear throughout the rest of this test. This is a good well and we can't foresee any problems with it. A new well seal was installed since this well did not have one.

IF WE CAN BE OF FUTHER ASSISTANCE FEEL FREE TO CALL US AT (719) 748-8669 OR  
687-9364

THANK YOU



ROBERT B. GILLEN  
LICENSE # 1335

WELL PRODUCTION RATE IS NOT  
CERTIFIED/WARRANTED BEYOND  
DATE TESTED